



SAFETY NOTICE



- 1. THIS UNIT SHOULD ONLY BE CONNECTED/DISCONNECTED/MOVED BY A COMPETENT ADULT**
- 2. THE SUPPLY CABLE SHOULD BE CHECKED DAILY FOR DAMAGE, IF THE CABLE IS DAMAGED DO NOT USE**
- 3. THIS UNIT SHOULD BE PLUGGED INTO A SWITCHED SOCKET WITH AN RCD**
- 4. THE SOCKET SHOULD BE SWITCHED OFF PRIOR TO REMOVING THE PLUG**
- 5. THE UNIT SHOULD BE PAT TESTED EVERY 12 MONTHS**
- 6. BE AWARE THIS UNIT MAY HAVE 2 MAINS CABLES**
- 7. ALWAYS SECURE THE POWER CABLE WHEN MOVING TO AVOID DAMAGE**